

LNL-X3300

Intelligent System Controller








Overview

The LNL-X3300 Intelligent System Controller (ISC) is designed for advanced access control applications. As the access control engine for the OnGuard® system, the ISC provides power and functionality. The ISC can communicate to the host computer in a single- or dual-path Ethernet configuration. Multiple combinations of Input Control Modules, Output Control Modules, and Card Reader Interface Modules (up to 64 devices) can be configured.

Utilizing its native Ethernet communications and an advanced 32-bit processor, the LNL-X3300 can communicate upstream to the host computer through its primary Ethernet port, with throughput up to 8 times greater than the fastest serial connections. Additionally, the LNL-X3300 offers an optional secondary communications option, through a USB-to-Ethernet connection.


The LNL-X3300 can store up to 500,000 cardholders in nonvolatile flash memory, and supports selective download for larger cardholder databases. The two downstream RS-485 2-wire ports can be used to connect up to 64 devices (64 doors) in many combinations of LNL-1100, LNL-1200, LNL-1300, and LNL-1320 as well as to older devices like the LNL-500B and LNL-500W modules.



Features & Functionality

- DHCP and fixed-IP addressing supported
- DNS device naming through DHCP extended commands
- · Optional Secondary NIC, USB port (2.0) with optional adapter
- 15 MB of available on-board, non-volatile flash memory
- Battery-backed, non-volatile storage of 50,000 events
- Configurable option for Data-at-Rest encryption
- · Firmware stored in flash memory, background download of firmware updates supported
- · 12 or 24 VDC input power
- Supports up to 16 badge formats
- Biometric template storage support
- Up to 32,000 access level permissions
- · 255 holidays with grouping
- · 255 timezones, each with 6 intervals
- Elevator control support for up to 128 floors
- Supports up to 9-digit user PIN codes
- Status LEDs for heartbeat & battery status, upstream and downstream communication, and memory write status
- Two dedicated inputs for tamper and power failure status
- · Advanced Encryption Standard (AES) 256-bit algorithm for communication to LenelS2 Series 3 reader and I/O modules; AES 128 bit encryption with LenelS2 Series 2 reader and I/O modules
- AES128 or TLS 1.2 (with AES256 support) communication to OnGuard

System Diagram



Specifications The interface is for use in low voltage, Class 2 Circuits only. The installation of this device must comply with all local fire and electrical codes.

Primary Power

12 to 24 VDC ± 10%, 250 mA maximum

Primary Host Communication

Secondary Host Communication

Serial I/O Device

12 to 24 VDC ± 10%, 250 mA maximum

Ethernet: 10-BaseT/100Base-TX

USB port (2.0) with optional adapter: pluggable model USB2-OTGE100

Two each: 2-wire RS-485, 2,400 to 115,200 bps, asynchronous, half-duplex, 1 start bit, 8 data bits, and 1 stop bit

Two non-supervised, dedicated for cabinet tamper and power fault

Inputs	Two non-supe
прис	monitoring

Power and Relays	One twisted pair, 18 AWG
Ethernet	CAT-5, minimum
RS-485	One twisted pair with drain wire and shield, 120 ohm impedance, 24 AWG, 4,000 ft. (1,219m) maximum

Mechanical

	Dimensions	5.0 W x 6.0 L x 1.0 H in. (127 x 152.4 x 25mm)
	Weight	4.1 oz. (115g) nominal
e a company of the co		

Environmenta

Cable Requirements

-55° to +85° C, storage
0° to +70° C, operating
5 to 95% RHNC
at 12 VDC, 10.2 BTU/hr
at 24 VDC, 12.3 BTU/hr
FCC Part 15, CE, RoHS, UL 294, UL 2610

Parts and Spare Parts

Part No.	Description
LNL-X3300	15 MB on-board flash memory available for cardholder database; 50,000 event battery backed RAM for event log.
USB2- OTGE100	USB-to-Ethernet converter, for LNL-X Series Controllers only. Provides optional Secondary NIC connection. Second NIC should be on different subnet than primary NIC.



LenelS2.com

(866) 788-5095

Specifications subject to change without notice.

© 2024 Honeywell International Inc. All Rights Reserved. All trademarks and service marks referred herein are property of their respective owners. 2024/07